

# CITY OF JOLIET

## INTEROFFICE MEMORANDUM

July 25, 2022

**TO:** Public Service Committee  
**FROM:** Allison Swisher, P.E., Director of Public Utilities  
**SUBJECT:** Report on Utilities' Maintenance Activities

---

The following maintenance activities have been conducted since last reported at the July 5, 2022 Public Service Meeting:

Hydrant Repairs: Ten hydrants have been repaired. There are currently 25 out of service hydrants (0.3% of 8351) and 18 hydrants that are operational but need repairs (0.2% of 8351).

Valve Repairs: Two valves have been reset or repaired.

Water Main Breaks: Fifteen water main breaks have been repaired. For 2022, there have been a total of 137 water main breaks. For the same period of time, we had 140 water main breaks in 2021, 84 in 2020, 175 in 2019, and 140 in 2018.

There was one new contracted service. Austin Tyler completed a point repair at 255-257 Wilson Avenue. The repair was approximately 9-13 feet deep on a 42" diameter sewer main line.