

CITY OF JOLIET

INTEROFFICE MEMORANDUM

March 22, 2024

TO: Public Service Committee

FROM: Allison Swisher, P.E., Director of Public Utilities

SUBJECT: Report on Utilities' Maintenance Activities

The following maintenance activities have been conducted since last reported at the March 4, 2024, Public Service Meeting:

Hydrant Repairs: Eleven hydrants have been repaired. There are currently 41 out of service hydrants (0.5% of 8351) and 39 hydrants that are operational but need repairs (0.5% of 8351).

Valve Repairs: Seven valves have been reset or repaired.

Water Main Breaks: Eight water main breaks have been repaired. For 2024, there have been a total of 47 water main breaks. For the same period of time, we had 26 water main breaks in 2023, 88 in 2022, 86 in 2021, 34 in 2020, 98 in 2019, and 98 in 2018.

There was one new contracted service. A lead service repair off the two inch cast iron water main at 1033 Charlesworth Avenue was completed with assistance from Austin Tyler's plumber.